

Energy performance certificate (EPC)

Roadrock Music International
Ltd
Unit A, Chesham Close
ROMFORD
RM7 7PJ

Energy rating

E

Valid until 14 May 2029

Certificate number

0520-0231-3099-0595-

5002

Property type	B1 Offices and Workshop businesses
----------------------	--

Total floor area	425 square metres
-------------------------	-------------------

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.


If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

You can read [guidance for landlords on the regulations and exemptions](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/105222/Dom_Private_Rented_Property_Minimum_Standard_-_Landlord_Guidance.pdf) (https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/105222/Dom_Private_Rented_Property_Minimum_Standard_-_Landlord_Guidance.pdf).

Energy efficiency rating for this property

This property's current energy rating is E.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

29 | B

If typical of the existing stock

86 | D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO₂/m² per year)	69.48
Primary energy use (kWh/m² per year)	410.98

▶ What is primary energy use?

Primary energy use is a measure of the energy required for lighting, heating and hot water in a property. The calculation includes:

- the efficiency of the property's heating system
- power station efficiency for electricity
- the energy used to produce the fuel and deliver it to the property

Recommendation report