Energy performance certificate (EPC) recommendation report

First Floor And Second Floor 138 South Street ROMFORD RM1 1TE Report number **2707-8536-7010-1138-1601**

Valid until
12 March 2033

Energy rating and EPC

This property's current energy rating is C.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Make these changes to improve the property's energy efficiency.

Recommended improvements are grouped by the estimated time it would take for the change to pay for itself. The assessor may also make additional recommendations.

Each recommendation is marked as low, medium or high. This shows the potential impact of the change on reducing the property's carbon emissions.

Changes that pay for themselves within 3 years

| Recommendation | Potential impact |
|--|---------------------|
| Consider replacing T8 lamps with retrofit T5 conversion kit. | High |
| Changes that pay for themselves within 3 to 7 years Recommendation | Potential impact |
| Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required. | Low |
| Changes that pay for themselves in more than 7 years | |
| Recommendation | Potential impact |
| Add optimum start/stop to the heating system. | Medium |
| Add weather compensation controls to heating system. | |
| Consider installing solar water heating. | Low |
| Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation. | Medium |
| Consider installing a ground source heat pump. | |

Property and report details

| Report issued on | 13 March 2023 |
|-------------------------|---|
| Total useful floor area | 129 square metres |
| Building environment | Mixed-mode with Natural Ventilation |
| Calculation tool | Property Tectonics Ltd, Lifespan SBEM, v6.1.c.0, SBEM, v6.1.c.0 |
| | |

Assessor's details

| Assessor's name | David Fountain |
|------------------------|---|
| Telephone | |
| Email | david@grantacommercial.co.uk |
| Employer's name | Granta |
| Employer's address | 16 St John's Street, Duxford, Cambridge, CB22 4RA |
| Assessor ID | STER500122 |
| Assessor's declaration | The assessor is not related to the owner of the property. |
| Accreditation scheme | Sterling Accreditation Ltd |
| | |